Adaptive Economic Model Predictive Control for linear systems with performance guarantees

Maximilian Degner^{1,2}, Raffaele Soloperto¹, Melanie N. Zeilinger², John Lygeros¹, Johannes Köhler²

Abstract—We present a model predictive control (MPC) formulation to directly optimize economic criteria for linear constrained systems subject to disturbances and uncertain model parameters. The proposed formulation combines a certainty equivalent economic MPC with a simple least-squares parameter adaptation. For the resulting adaptive economic MPC scheme, we derive strong asymptotic and transient performance guarantees. We provide a numerical example involving building temperature control and demonstrate performance benefits of online parameter adaptation.

I. INTRODUCTION

Model predictive control (MPC) is an optimization-based control strategy that is applicable to general MIMO systems, explicitly accounts for constraints, and optimizes general performance criteria [1]. However, deployment strategies of MPC typically rely on a sequential design and hierarchical architecture that might limit performance: First, a prediction model is obtained through physical modeling or identification based on experimental data, which is often the most costly part in commissioning MPC [2]. Then, during online operation, a real-time optimization (RTO) layer computes economically optimal steady-states which are then stabilized by the MPC [3]. Changing environments or wear can deteriorate the accuracy of the offline obtained model, and thus jeopardize the performance of the MPC. Furthermore, the decomposition with the RTO-layer limits flexibility, and thus overall efficiency, especially in case of persistent disturbances or frequent changes in operating conditions. This paper addresses both issues by directly optimizing economic performance and using online model adaptation.

A. Related work

Economic MPC formulations [3]–[6] directly minimize the economic objective over the prediction horizon to improve performance. Exemplary applications for this methodology are minimizing energy consumption in heating, ventilation, and air conditioning (HVAC) [7], increasing production in chemical plants [3] or flexible manufacturing system [8]. One of the key theoretical results in economic MPC is that, on average, the closed-loop performance is no worse than the performance at the optimal steady-state [9], [10], i.e., at worst we obtain an asymptotic performance comparable to a tracking MPC. Stronger transient performance bounds

¹Automatic Control Laboratory, ETH Zürich

relative to the infinite-horizon optimal solution are obtained in [11], [12], see also [13]–[15] for robust performance bounds under bounded disturbances.

Adaptive MPC uses online measurements to adapt the model parameters, thus relying less on the initial parameter identification and ensuring reliable operation under online changes in system behavior. While the benefits of adaptive MPC methods have been demonstrated empirically [16], the development of adaptive MPC theory has received less attention [17]. Robust adaptive MPC schemes [18]-[20] combine a robust MPC design with set-membership updates to reduce conservatism in constraint handling, see also [21]-[23] for nonlinear systems. In [18], finite-gain \mathcal{L}_2 stability is shown by updating parameters in the cost with a leastmean square (LMS) filter. In [22], it is shown that the same stability result applies to linearly parameterized nonlinear systems under suitable regularity conditions. Convergence results for more general non-parametric model updates are shown in [24], [25].

Adaptive economic MPC: The integration of online measurements to ensure optimality of the steady-state is studied in the framework of modifier adaptation [26]. MPC approaches that integrate adaptation to improve the steadystate optimization are provided in [6], [27]–[29]. A nonlinear robust adaptive economic MPC scheme is proposed in [30, Chap. 3], however, no performance guarantees are derived. Overall, theoretical performance guarantees for economic MPC with online model adaptation require further study.

B. Contribution

In this paper,we consider linear constrained systems subject to disturbances and uncertain model parameters with the goal to minimize a convex linear-quadratic economic cost. Our main assumptions are open-loop stability of the linear system and relaxation of state constraints with soft penalties. For this problem, we propose an adaptive economic MPC (AE-MPC) scheme which:

- uses a certainty-equivalent economic MPC scheme with a linear-quadratic terminal cost in combination with the LMS parameter adaptation from [18].
- for finite-energy disturbances, recovers the asymptotic performance guarantees from nominal economic MPC [9], despite the possibly large initial error in the model parameters (Theorem 3).
- for the case of bounded disturbances, ensures a more general transient performance bound (Theorem 5) that depends linearly on the energy of the disturbances.

²Institute for Dynamic Systems and Control, ETH Zürich

Johannes Köhler was supported by the Swiss National Science Foundation under NCCR Automation (grant agreement 51NF40 180545).

Raffaele Soloperto is supported by the European Research Council under the H2020 Advanced Grant no. 787845 (OCAL).

We demonstrate the performance benefits of the proposed AE-MPC scheme with a numerical example involving building temperature control in comparison to an economic MPC without parameter adaptation.

C. Outline and Notation

We first define the problem setup (Sec. II) and present the proposed AE-MPC scheme (Sec. III). Then we provide a theoretical performance analysis and discussion (Sec. IV), and demonstrate these results with a simulation of a simple building temperature control problem (Sec. V).

We denote the 1-norm and 2-norm of a vector $x \in \mathbb{R}^n$ by $||x||_1$ and ||x||, respectively. The weighted norm with $Q \in \mathbb{R}^{n \times n}$ is denoted by $||x||_Q^2 = x^\top Qx$. The spectral norm of a matrix $A \in \mathbb{R}^{n \times m}$ is given by $||A|| = \sqrt{\lambda_{\max}(A^\top A)}$, where λ_{\max} denoted the maximal eigenvalue. A positive semidefinite matrix R is denoted by $R \succeq 0$ and a positive definite matrix Q is denoted by $Q \succ 0$. The identity matrix of size $n \times n$ is signified by I_n . At time k, we denote a prediction of quantity x for time k + j as $x_{j|k}$. The *i*-th element of a vector $x \in \mathbb{R}^n$ is represented by $[x]_i$. A function α is of class \mathcal{K}_{∞} , if $\alpha : \mathbb{R}_{\geq 0} \to \mathbb{R}_{\geq 0}, \alpha(0) = 0, \lim_{s \to \infty} \alpha(s) = \infty$, and α strictly increasing and continuous. The non-negative integers are represented by \mathbb{N} and $\mathbb{N}_{[a,b]} = \{n \in \mathbb{N} | a \le n \le b\}$.

II. PROBLEM SETUP

In the following, we consider discrete-time linear systems that are subject to additive disturbances and parametric uncertainty. The dynamics are given by

$$x_{k+1} = A(\theta^*)x_k + B(\theta^*)u_k + w_k,$$
 (1)

where $x_k \in \mathbb{R}^n$, $u_k \in \mathbb{R}^m$, $w_k \in \mathbb{R}^n$ are the states, control inputs, and disturbances at time $k \in \mathbb{N}$, respectively. The parameter $\theta \in \mathbb{R}^d$ enters (1) in an affine way, i.e.,

$$A(\theta) = A_0 + \sum_{i=1}^{d} A_i \cdot [\theta]_i, \ B(\theta) = B_0 + \sum_{i=1}^{d} B_i \cdot [\theta]_i,$$

where $A_i \in \mathbb{R}^{n \times n}, B_i \in \mathbb{R}^{n \times m} \quad \forall i \in \mathbb{N}_{[0,d]}$. The true parameter θ^* is unknown but constant over time and lies in a known compact, polytopic set Θ . We assume that we have an initial parameter estimate $\hat{\theta}_0 \in \Theta$.

We study the case where we want to satisfy the following state and input constraints

$$(x_k, u_k) \in \mathbb{X} \times \mathbb{U}, \quad \forall k \in \mathbb{N},$$
 (2)

where $\mathbb{X} = \{x \in \mathbb{R}^n | Hx \leq h\}$, $h \in \mathbb{R}^q_{\geq 0}$, \mathbb{U} is a compact polytope, and $(0,0) \in \mathbb{X} \times \mathbb{U}$. The goal is to minimize the following convex economic cost

$$\ell_{\rm eco}(x,u) = \|x\|_Q^2 + \|u\|_R^2 + q^{\top}x + r^{\top}u, \qquad (3)$$

with Q, $R \succeq 0$. To simplify the design, we soften the state constraints with a slack variable $s = \max\{Hx - h, 0\} \in \mathbb{R}^{q}_{\geq 0}$, which will be penalized by using the stage cost

$$\ell(x, u, s) = \ell_{\rm eco}(x, u) + \|s\|_{\Lambda}^2, \tag{4}$$

with a slack penalty $\Lambda \succ 0$. For simplicity of exposition, we consider a diagonal matrix Λ .

Assumption 1 (Stable system). The system is open-loop exponentially stable for all $\theta \in \Theta$ with a common Lyapunov function, i.e., $\exists P \succ 0$:

$$A(\theta)^{\top} P A(\theta) + I \preceq P \ \forall \theta \in \Theta.$$

Remark 1 (Open-loop stability and soft-constraints). By restricting the problem setup to open-loop stable systems (Assumption 1) and soft-state constraints, the proposed method can be applied even if the initial parameter error and the disturbances are large. Notably, if sufficiently small bounds on parametric error and disturbances are known, both simplifications can be relaxed, see the discussion in Section IV-C.

We assume that some possibly conservative bound on the disturbances is known, i.e., $w_k \in \mathbb{W}, \forall k \in \mathbb{N}$ with \mathbb{W} compact. In combination with \mathbb{U} compact, $A(\theta^*)$ Schur stable (Assumption 1) and some finite x_0 , this implies that the closed-loop states x_k are uniformly bounded. Hence, we assume that some conservative upper-bound on the state is available, i.e., $x_k \in \mathbb{Z}, \forall k \in \mathbb{N}$ with a known compact set \mathbb{Z} .

III. METHOD

In this section, we describe the offline design and the online algorithm of the proposed adaptive economic MPC (AE-MPC) formulation. First, we provide the parameter adaptation scheme and its properties (Sec. III-A), then we construct a terminal cost (Sec. III-B), and finally we state the resulting AE-MPC scheme (Sec. III-C).

A. Parameter adaptation

Based on the initial estimate $\hat{\theta}_0 \in \Theta$ of the true parameter θ^* , we use the projected least-mean square (LMS) filter from [18] to adapt the parameter estimate $\hat{\theta}_k$ at every time instant $k \in \mathbb{N}$. Let us define the shorthand notation

$$D_k = D(x_k, u_k) = [A_1 x_k + B_1 u_k \dots A_p x_k + B_p u_k].$$

The prediction of the state one step in the future, made at time k, is denoted by $x_{1|k} = D_k \hat{\theta}_k$. The update equations of the LMS are

$$\tilde{\theta}_{k+1} = \hat{\theta}_k + \mu D_k^{\top} (x_{k+1} - x_{1|k}) = \hat{\theta}_k + \mu D_k^{\top} (D_k \cdot (\theta^* - \hat{\theta}_k) + w_k),$$
(5a)

$$\hat{\theta}_{k+1} = \underset{\theta \in \Theta}{\arg\min} \|\theta - \tilde{\theta}_{k+1}\|, \tag{5b}$$

where $\mu > 0$ is the update gain which is chosen such that

$$\frac{1}{\mu} \ge \sup_{(x,u) \in \mathbb{Z} \times \mathbb{U}} \|D(x,u)\|^2.$$
(6)

The following proposition is an adaption of [18, Lemma 5] and shows that the cumulated prediction error is bounded.

Proposition 1 (LMS bounds). Suppose that $x_k \in \mathbb{Z}$ and $u_k \in \mathbb{U}$ for all $k \in \mathbb{N}$. Then, for all $T \in \mathbb{N}$, it holds that

$$\sum_{k=0}^{T} \|\tilde{x}_{1|k}\|^2 \le \frac{1}{\mu} \|\hat{\theta}_0 - \theta^*\|^2 + \sum_{k=0}^{T} \|w_k\|^2, \qquad (7)$$

with the one-step parametric prediction error

$$\tilde{x}_{1|k} := D_k \cdot (\theta^* - \hat{\theta}_k).$$

Moreover, the difference between two successive parameter estimates satisfies

$$\|D(x,u)\| \cdot \|\hat{\theta}_{k+1} - \hat{\theta}_k\| \le \|\tilde{x}_{1|k} + w_k\|, \ \forall (x,u) \in \mathbb{Z} \times \mathbb{U}.$$
(8)

Proof. The proof of (7) can be found in [18, Lemma 5]. Inequality (8) stems from the fact that the projection operator is non-expansive (\diamond), and from using the Cauchy-Schwarz inequality and the triangle inequality at (\star):

$$\begin{aligned} \|\hat{\theta}_{k+1} - \hat{\theta}_{k}\| & \stackrel{(\diamond)}{\leq} \|\tilde{\theta}_{k+1} - \hat{\theta}_{k}\| \\ & \stackrel{(5a),(\star)}{\leq} \mu \|D_{k}\| \cdot \|\tilde{x}_{1|k} + w_{k}\|. \end{aligned} \tag{9}$$

Multiplying both sides with ||D(x, u)|| and using our choice of μ (cf. (6)) gives the result.

B. Terminal cost design

MPC schemes require a terminal cost for closed-loop performance guarantees [1], [10]. In this section, we extend the standard design procedure in [10] to incorporate online parameter adaptation and show how to design a simple terminal cost $\ell_f(x, \theta)$. We center the design of terminal cost around the steady-state (x, u) = 0 for simplicity. Hence, all theoretical guarantees will be relative to the performance at this steady state.

Proposition 2 (Terminal cost). Consider $P_f \in \mathbb{R}^{n \times n}$, $P_f \succ 0$ and the vector-valued function $p : \mathbb{R}^d \to \mathbb{R}^n$ satisfying:

$$A(\theta)^{\top} P_{\rm f} A(\theta) - P_{\rm f} + \bar{Q} \preceq 0, \quad \forall \theta \in \Theta,$$
 (10a)

$$p(\theta) = (I_n - A(\theta))^{-+}q, \qquad (10b)$$

with $\bar{Q} = Q + H^{\top} \Lambda H$. Then, for all $x \in \mathbb{R}^n, \theta \in \Theta$, the terminal cost $\ell_{\mathrm{f}}(x, \theta) = \|x\|_{P_{\mathrm{f}}}^2 + p(\theta)^{\top} x$ satisfies

$$\ell_{\rm f}(A(\theta)x,\theta) - \ell_{\rm f}(x,\theta) \le -\ell(x,0,s),\tag{11}$$

with $s = \max\{Hx - h, 0\}$.

Proof. First, note that $\|\max\{Hx - h, 0\}\|_{\Lambda}^2 \leq \|Hx\|_{\Lambda}^2$ for all $x \in \mathbb{R}^n$ with the diagonal matrix Λ . Thus,

$$\ell(x, u, s) \le \|x\|_{\bar{Q}}^2 + \|u\|_R^2 + q^\top x + r^\top u, \qquad (12)$$

with $\bar{Q} = Q + H^{\top} \Lambda H$. To show that (11) holds, we use the shorthand $A_{\theta} = A(\theta)$ and expand the left side:

$$\ell_{\mathrm{f}}(A_{\theta}x,\theta) - \ell_{\mathrm{f}}(x,\theta)$$

$$= \|A_{\theta}x\|_{P_{\mathrm{f}}}^{2} + p(\theta)^{\top}A_{\theta}x - \|x\|_{P_{\mathrm{f}}}^{2} - p(\theta)^{\top}x$$

$$\stackrel{(10b)}{=} -q^{\top}x + (A_{\theta}x)^{\top}P_{\mathrm{f}}(A_{\theta}x) - x^{\top}P_{\mathrm{f}}x$$

$$\stackrel{(10a)}{\leq} -q^{\top}x - x^{\top}\bar{Q}x \stackrel{(12)}{\leq} -\ell(x,0,s).$$

Due to Assumption 1, we can compute a matrix $P_{\rm f}$ satisfying (10a) using a semi-definite program with the vertices of the polytope Θ , see, e.g. [19, Eq. (33)]. The vector $p(\theta)$ needs to be computed online for each parameter estimate $\hat{\theta}_k$.

C. Adaptive Economic MPC scheme

At time $k \in \mathbb{N}$, the proposed AE-MPC is given by

$$V_N^*(x_k, \hat{\theta}_k) = \min_{u_{\cdot|k}, \hat{x}_{\cdot|k}, s_{\cdot|k}} \sum_{j=0}^{N-1} \ell(\hat{x}_{j|k}, u_{j|k}, s_{j|k}) + \ell_f(\hat{x}_N, \hat{\theta}_k)$$
(13a)

subject to
$$\hat{x}_{j+1|k} = A(\hat{\theta}_k)x_{j|k} + B(\hat{\theta}_k)u_{j|k}$$
 (13b)

$$H\hat{x}_{i|k} \le h + s_{i|k} \tag{13c}$$

$$u_{i|k} \in \mathbb{U} \tag{13d}$$

$$\hat{x}_{0|k} = x_k \tag{13e}$$

$$\forall j \in \mathbb{N}_{[0,N-1]}.$$

With (13b), we predict the system's trajectory with the LMS estimate and initialize these predictions with the measurement of the current state (13e) over the prediction horizon $N \in \mathbb{N}$. The soft state constraints are given in (13c), the input constraints in (13d), and we minimize the economic cost and the penalty of slack variables together with the terminal cost by using the cost function (13a). The solution of the optimization problem (13) is denoted by $u_{\cdot|k}^*$, $\hat{x}_{\cdot|k}^*$, $s_{\cdot|k}^*$ and the optimal control input $u_{0|k}^*$ is applied to the system (1). Note that Problem (13) is a convex quadratic program which is feasible for all $(x_k, \hat{\theta}_k)$ since no hard state or terminal set constraints are imposed.

A summary of the offline design and the online computations is given by Algorithm 1.

Algorithm 1 Adaptive Economic MPC
Choose μ as in (6), compute $P_{\rm f}$ as in (10a).
for $k\in\mathbb{N}$ do
Measure the state x_k .
Adapt the parameter $\hat{\theta}_k \in \Theta$ using LMS (5).
Update linear terminal cost $p^{\top} \leftarrow q^{\top} (I_n - A(\hat{\theta}_k))^{-1}$.
Solve the optimization problem (13).
Apply the control input $u_k \leftarrow u_{0 k}^*$.
end for

IV. THEORETICAL ANALYSIS

In this section, we present asymptotic and transient performance guarantees for asymptotic and transient bounds on the disturbances w_k . First, we derive an asymptotic performance bound assuming finite-energy disturbances (Sec. IV-A). Then, we consider point-wise bounded disturbances and obtain a transient performance bound (Sec IV-B). Further discussion of the relation between the two bounds is given in Section IV-C.

A. Asymptotic performance

In the following, we provide an asymptotic average performance bound for finite-energy disturbances.

Assumption 2 (Finite-energy disturbances). There exists a finite constant S_w , such that

$$\lim_{T \to \infty} \sum_{k=0}^{T} \|w_k\|^2 \le S_{\rm w}.$$
 (14)

Theorem 3 (Asymptotic average performance). Let Assumptions 1 and 2 hold. Then, the closed-loop system resulting from Algorithm 1 satisfies

$$\limsup_{T \to \infty} \frac{\sum_{k=0}^{T-1} \ell(x_k, u_k, s_{0|k}^*)}{T} \le 0.$$
(15)

Proof. We first define a feasible candidate solution and provide a bound on the one-step decrease of the value function in (19). Then, we use the LMS properties (Prop. 1) and the finite-energy of the disturbances (Asm. 2) to show (15).

Candidate solution: Recall that $\hat{x}_{\cdot|k}^*$, $u_{\cdot|k}^*$, $s_{\cdot|k}^*$, denote the optimal solution to Problem (13) at time $k \in \mathbb{N}$ and let us denote $u_{N|k}^* = 0$, $\hat{x}_{N+1|k}^* = A(\hat{\theta}_k)\hat{x}_{N|k}^*$. We consider the candidate input sequence $u_{j|k+1} = u_{j+1|k}^*$, $j \in \mathbb{N}_{[0,N-1]}$. The corresponding state sequence $\hat{x}_{j|k+1}$, $j \in \mathbb{N}_{[0,N]}$ is given by $\hat{x}_{0|k+1} = x_{k+1}$ and using (13b) with $\hat{\theta}_{k+1}$; the slack variables are chosen as $s_{j|k+1} =$ $\max\{H\hat{x}_{j|k+1} - h, 0\}$. We denote $\ell_{j|k}^* = \ell(\hat{x}_{j|k}^*, u_{j|k}^*, s_{j|k}^*)$, $\ell_{j|k+1} = \ell(\hat{x}_{j|k+1}, u_{j|k+1}, s_{j|k+1})$.

Difference in cost: The increase of the value function V_N^* can be upper bounded by the cost of the (feasible) candidate sequence:

$$V_{N}^{*}(x_{k+1},\hat{\theta}_{k+1}) - V_{N}^{*}(x_{k},\hat{\theta}_{k}) + \ell_{0|k}^{*}$$

$$\leq \sum_{j=1}^{N-1} (\ell_{j-1|k+1} - \ell_{j|k}^{*}) + \ell_{N-1|k+1}$$

$$+ \ell_{N-1|k+1} + \ell_{f}(\hat{x}_{N|k+1},\hat{\theta}_{k+1}) - \ell_{f}(\hat{x}_{N|k}^{*},\hat{\theta}_{k}).$$
(16)

In the following, we first bound the increase due to disturbances and parameter update, and then bound the last terms using the properties of the terminal cost. Let $\Delta x_{j|k} = \hat{x}_{j-1|k+1} - \hat{x}_{j|k}^*$, $\Delta \theta_k = \hat{\theta}_{k+1} - \hat{\theta}_k$, and recall that the states, inputs, and parameters all lie in some compact sets. Hence, the linear quadratic stage cost from (4) has a uniform Lipschitz constant $L \ge 0$:

$$\Delta \ell_{j|k} := \ell_{j-1|k+1} - \ell_{j|k}^* \le L \|\Delta x_{j|k}\|.$$
(17)

Similarly, ℓ_f is Lipschitz-continuous¹ with some uniform constant $L_f \ge 0$, which implies

$$\ell_{f}(\hat{x}_{N|k+1}, \hat{\theta}_{k+1}) - \ell_{f}(\hat{x}_{N|k}^{*}, \hat{\theta}_{k})$$

$$\stackrel{(11)}{\leq} \ell_{f}(\hat{x}_{N|k+1}, \hat{\theta}_{k+1}) - \ell_{f}(\hat{x}_{N+1|k}^{*}, \hat{\theta}_{k}) - \ell_{N|k}^{*}$$

$$\leq L_{f}(\|\Delta x_{N+1|k}\| + \|\Delta \theta_{k}\|) - \ell_{N|k}^{*},$$
(18)

¹Note that Condition (10a) ensures stability of $A(\theta)$ and that $\|(I - A(\theta))^{-1}\|$ is uniformly bounded. Given that also $A(\theta)$ is affine in θ , we have that $p(\theta)$ in (10b) is Lipschitz continuous w.r.t. $\theta \in \Theta$. Thus, $\ell_{\rm f}$ is Lipschitz w.r.t. (x, θ) on the compact set $(x, \theta) \in \mathbb{Z} \times \Theta$.

where we denoted $\ell_{N|k}^* = \ell(\hat{x}_{N|k}^*, 0, s_{N|k}^*)$ and $s_{N|k}^* = \max\{Hx_{N|k}^* - h, 0\}$. Combining (16) – (18) gives

$$V_{N}^{*}(x_{k+1}, \hat{\theta}_{k+1}) - V_{N}^{*}(x_{k}, \hat{\theta}_{k}) + \ell_{0|k}^{*}$$

$$\stackrel{(16)}{\leq} \sum_{j=1}^{N-1} \Delta \ell_{j|k}$$

$$+ \ell_{N-1|k+1} + \ell_{f}(\hat{x}_{N|k+1}, \hat{\theta}_{k+1}) - \ell_{f}(\hat{x}_{N|k}^{*}, \hat{\theta}_{k})$$

$$\stackrel{(18)}{\leq} \sum_{j=1}^{N} \Delta \ell_{j|k} + L_{f} \|\Delta x_{N+1|k}\| + L_{f} \|\Delta \theta_{k}\|$$

$$\stackrel{(17)}{\leq} L_{f} \|\Delta x_{N+1|k}\| + L_{f} \|\Delta \theta_{k}\| + L \cdot \sum_{j=1}^{N} \|\Delta x_{j|k}\|.$$
(19)

Combination with the LMS estimator: Next, we use the LMS properties to further bound the terms in (19). Similar to [18], we can bound $\Delta x_{i|k}$:

$$\Delta x_{j|k} = A(\hat{\theta}_{k+1})^{j-1} (w_k + \tilde{x}_{1|k}) + \sum_{i=1}^{j-1} A(\hat{\theta}_{k+1})^{j-1-i} D(\hat{x}_{i|k}, u_{i|k}) \cdot \Delta \theta_k,$$
(20)
$$\|\Delta x_{j|k}\| \stackrel{(20),(8)}{\leq} \left(\sum_{i=0}^{j-1} \|A(\hat{\theta}_{k+1})^{j-1-i}\| \right) \|w_k + \tilde{x}_{1|k}\|.$$
(21)

Let us denote

$$C'_{A} := \max_{j \in \mathbb{N}_{[1,N+1]}, \theta \in \Theta} \sum_{i=0}^{j-1} \|A(\theta)^{j-1-i}\|.$$
(22)

Combining the bounds and summing both sides from k = 0 to k = T - 1 yields

$$V_{N}^{*}(x_{T}, \hat{\theta}_{T}) - V_{N}^{*}(x_{0}, \hat{\theta}_{0}) + \sum_{k=0}^{T-1} \ell_{0|k}^{*}$$

$$\stackrel{(19)}{\leq} \sum_{k=0}^{T-1} \left[L_{f} \|\Delta x_{N+1|k}\| + L_{f} \|\Delta \theta_{k}\| + L \cdot \sum_{j=1}^{N} \|\Delta x_{j|k}\| \right]$$

$$\stackrel{(9),(6)}{\leq} \sum_{k=0}^{T-1} \left[L_{f} \|\Delta x_{N+1|k}\| + L_{f} \sqrt{\mu} \|\tilde{x}_{1|k} + w_{k}\| + L \sum_{j=1}^{N} \|\Delta x_{j|k}\| \right]$$

$$+ L \sum_{j=1}^{N} \|\Delta x_{j|k}\| \right]$$

$$\stackrel{(21),(22)}{\leq} C_{A} \sum_{k=0}^{T-1} \left[\|w_{k}\| + \|\tilde{x}_{1|k}\| \right], \qquad (23)$$

where the last step used the triangular inequality and $C_A := [L_f + (N-1)L]C'_A + L_f\sqrt{\mu}$. Note that

$$\lim_{T \to \infty} \frac{-V_N^*(x_T, \hat{\theta}_T) + V_N^*(x_0, \hat{\theta}_0)}{T} = 0$$

since $V_N^*(x_k, \hat{\theta}_k)$ admits a uniform bound using $x_k \in \mathbb{Z}$, $\hat{\theta}_k \in \Theta$, and compactness of \mathbb{Z} and Θ . Thanks to

Assumption 2, Lemma 7 from the Appendix ensures

$$\lim_{T \to \infty} \frac{\sum_{k=0}^{T-1} \|\tilde{x}_{1|k}\| + \|w_k\|}{T} = 0.$$
 (24)

Thus, taking the limit $T \to \infty$ gives the final result

$$-\limsup_{T \to \infty} \frac{V_N^*(x_T, \hat{\theta}_T) - V_N^*(x_0, \hat{\theta}_0)}{T} + \limsup_{T \to \infty} \frac{\sum_{k=0}^{T-1} \ell_{0|k}^*}{T}$$

$$\stackrel{(23)}{\leq} \limsup_{T \to \infty} \sum_{k=0}^{T-1} \frac{1}{T} \left[C_A \| w_k \| + C_A \| \tilde{x}_{1|k} \| \right] \stackrel{(14), (24)}{\leq} 0,$$
which shows (15).

which shows (15).

The asymptotic performance bound ensures that on average, the closed-loop system will not perform worse than the operation at the origin, independent of the magnitude of the initial parameter error.

In the special case that the economic cost $\ell_{eco}(x, u)$ is positive definite, we recover an adaptive MPC with a tracking objective [18], and Theorem 3 recovers the stability result in [18, Corollary 16].

Corollary 4 (Asymptotic convergence). Let Assumptions 1 and 2 hold and suppose $\ell(x, u, s)$ is positive definite, i.e. $Q, R \succ 0, q = 0, r = 0$. Then, $\lim_{k\to\infty} ||x_k|| = 0$ for the closed-loop system resulting from Algorithm 1.

B. Transient performance bound

The previously shown asymptotic average performance does not allow for a statement about the AE-MPC's transient performance, i.e., its performance over a finite time T. In this subsection, we study the finite-time behavior in more detail.

Assumption 3 (Point-wise bounded disturbances). There exists a constant $\bar{w} > 0$ such that

$$\sum_{k=0}^{T-1} \|w_k\|^2 \le T\bar{w}^2 \quad \forall T \in \mathbb{N}.$$
(25)

Under Assumption 3, the disturbances are bounded by a uniform constant at all times. This is weaker than assuming finite-energy, because we do not require $||w_k||^2 \rightarrow 0$ for $k \to \infty$.

Theorem 5 (Transient performance bound). Let Assumptions 1 and 3 hold. Then, there exist uniform constants $C_V, C_A \geq 0$ such that for all $T \in \mathbb{N}$, the closed-loop system resulting from Algorithm 1 satisfies

$$\sum_{k=0}^{T-1} \ell(x_k, u_k, s_{0|k}^*)$$

$$\leq C_V + \bar{w} \cdot 2C_A T + C_A \frac{1}{\sqrt{\mu}} \|\hat{\theta}_0 - \theta^*\| \sqrt{T}.$$
(26)

Proof. First, note that the derivation of (23) in the proof of Theorem 3 remains valid with the bound of Assumption 3. Using the LMS parameter estimate yields

$$\sum_{k=0}^{T-1} \|\tilde{x}_{1|k}\|^2 \stackrel{(7),(25)}{\leq} T\bar{w}^2 + \frac{1}{\mu} \|\hat{\theta}_0 - \theta^*\|^2.$$
(27)

The one-step prediction error $\tilde{x}_{1|k}$ satisfies

$$\sum_{k=0}^{T-1} \|\tilde{x}_{1|k}\| \leq \sqrt{T} \sqrt{\sum_{k=0}^{T-1} \|\tilde{x}_{1|k}\|^2}$$

$$\stackrel{(27)}{\leq} T\bar{w} + \sqrt{\frac{T}{\mu}} \|\hat{\theta}_0 - \theta^*\|,$$
(28)

where the first inequality used the fact that $||X||_1 \le \sqrt{T} ||X||$ for any $X \in \mathbb{R}^T$ with $X_i = \|\tilde{x}_{1|i}\|$ and the second inequality makes use of $\sqrt{a+b} \leq \sqrt{a} + \sqrt{b}$ for any $a, b \geq 0$. Similarly, for the disturbances w_k we obtain

$$\sum_{k=0}^{T-1} \|w_k\| \le \sqrt{T} \sqrt{\sum_{k=0}^{T-1} \|w_k\|^2} \stackrel{(25)}{\le} \sqrt{T} \sqrt{T\bar{w}^2} = T\bar{w}.$$
 (29)

Next, we combine these transient bounds with (23) to obtain the transient performance bound:

$$V_N^*(x_T, \theta_T) - V_N^*(x_0, \hat{\theta}_0)$$

$$\stackrel{(23)}{\leq} \sum_{k=0}^{T-1} \left[-\ell_{0|k}^* + C_A \|\tilde{x}_{1|k}\| + C_A \|w_k\| \right]$$

$$\stackrel{(28),(29)}{\leq} \sum_{k=0}^{T-1} \left[-\ell_{0|k}^* \right] + C_A \sqrt{\frac{T}{\mu}} \|\hat{\theta}_0 - \theta^*\| + 2C_A \bar{w}T,$$

where C_A is defined after (23). Defining the uniform constant $-C_V \leq V_N^*(x_k, \theta_k) - V_N^*(x_0, \theta_0) \ \forall k \in \mathbb{N}, \text{ using compact-}$ ness of Θ and \mathbb{Z} , yields (26).

C. Discussion

The asymptotic performance bound of Theorem 3 shows that on average, our AE-MPC scheme performs no worse than operating the system at the origin. Our performance bound is relative to the performance at the origin due to centering the terminal cost around it (cf. Prop. 2). Even with bounded energy disturbances and uncertain initial parameters $\hat{\theta}_0 \neq \theta^*$, Theorem 3 establishes the same asymptotic performance guarantees as economic MPC without disturbances and with perfectly known parameters [10, Theorem 18]. The transient performance bound of Theorem 5 provides insight into the behavior under persistent disturbances. This transient performance bounds depends linearly depends on the magnitude of the disturbances \bar{w} . Furthermore, the system's transient performance depends on the initial parameter error. For $\bar{w} \to 0$ and $T \to \infty$, the transient performance bound (Thm. 5) recovers the asymptotic performance bound (Thm. 3).

The AE-MPC scheme considers the special case of soft state constraints which is useful for a variety of systems (e.g., temperature control). Its implementation is neither conceptually nor computationally more complex than implementing nominal MPC with soft constraints. We expect that the MPC scheme could be extended with a robust tube MPC formulation (e.g., [19]) to ensure robust constraint satisfaction and relax open-loop stability to stabilizability of $(A(\theta), B(\theta)).$

V. NUMERICAL EXAMPLE

We demonstrate the theoretical results using a simple building temperature control example and study the performance benefits of online adaptation for economic MPC. The corresponding MATLAB code is available online.²

Model and setup: We model the thermal dynamics of a single temperature zone in a building using a 2R2C-model [31]. The discrete-time model equations are given by

$$x_{k+1} = \begin{bmatrix} 1 - \frac{[\theta]_1}{a_1} & \frac{[\theta]_1}{a_1} \\ \frac{[\theta]_1}{a_2} & 1 - \frac{[\theta]_1 + [\theta]_2}{a_2} \end{bmatrix} x_k + \begin{bmatrix} \frac{1}{a_1} \\ 0 \end{bmatrix} u_k + \begin{bmatrix} \frac{1}{a_1} & 0 \\ 0 & \frac{[\theta]_2}{a_2} \end{bmatrix} w_k,$$

where $a_1 = 0.6125$, $a_2 = 21.12$ are constants that depend on the mass and the specific heat capacity of the wall materials. The room and wall temperature are the system's states $[x]_1$, $[x]_2$, respectively. The input u is the controllable heat flow into the room and the disturbances w consist of a disturbance heat flow $[w]_1$ (e.g., solar irradiation) and the outdoor temperature $[w]_2$. Normal operation, i.e., room temperature of 22° C and a nominal heat flow, corresponds to x = 0, u = 0. We use a sampling time of 10 minutes. The parameters θ reflect uncertainty in the thermal resistance. The parameter set is given $\Theta = [0.005, 0.144] \times [0.0004, 0.0075]$, with $\theta^* = [0.048, 0.0015]^{\top}$, $\hat{\theta}_0 = [0.1, 0.0075]^{\top}$. The disturbances take values according to

$$[w_k]_1 = 0.595 \left(\sin\left(\frac{2\pi}{24 \cdot 6}k\right) + \eta_k(-0.2, 0.2) \right),$$

$$[w_k]_2 = 7 \left(\sin\left(\frac{2\pi}{24 \cdot 6}(k-9)\right) + \eta_k(-0.5, 0.5) \right),$$

where $\eta_k(a, b)$ is the value of a random variable, uniformly distributed in the interval [a, b], and the phase shift k - 9models the fact that the outdoor temperature has a lag of 90 minutes relative to the solar irradiation. The frequency of the sinus is chosen such that its period is one day. To simplify the exposition and in accordance to the setting in this paper, the disturbances and their prediction are completely unknown to the controller.

We consider a heating problem and the room temperature is supposed to satisfy $[x]_1 \ge -1$. The input is constrained by $\mathbb{U} = [-0.8, 0.8]$ and the economic cost of the system is $\ell_{eco}(x, u) = x^{\top}Qx + r^{\top}u$, where Q = diag(500, 0), r =600. We want to keep the room temperature in a comfortable range and minimize the energy consumption; the factor r > 0reflects that increasing heating u increases the cost. The soft penalty on the temperature constraint is given by $\lambda = 10^5$ and we use a horizon of N = 18. The parameter update gain is $\mu = 5 \cdot 10^{-5}$, which satisfies (6) with the conservative bound $x_k \in \mathbb{Z} = \{[x]_1 \in [-20, 20], [x]_2 \in [-10, 10]\}$. Note that this problem satisfies the conditions in this paper, in particular, Assumption 1 and 3.

Results and comparison: In the following, we compare the performance of the proposed AE-MPC scheme (Alg. 1) to the performance of economic MPC (E-MPC) without parameter adaptation, i.e. $\hat{\theta}_k = \hat{\theta}_0$.



Fig. 1. Evolution of the parameter estimate (black solid). Bounds of the parameter set are the dashed black lines, and the dotted blue line is the true parameter value.



Fig. 2. Evolution of the state $[x]_1$ (top) and the input u (bottom) for the initial phase (left) and after parameter convergence (right). The constraint sets \mathbb{X}, \mathbb{U} are shown as black, dashed lines.

The evolution of the parameter estimate $\hat{\theta}_k$ is shown in Figure 1. The parameter estimates improve over a few of days and the error to the true parameters reduces. However, since the considered disturbances are correlated and no active excitation is performed, some residual bias remains. In Figure 2, we show the room temperature $[x]_1$ and the control input u during the first three days and after 20 days, with parameters largely converged. Due to the improved model, AE-MPC reduces constraint violations and temperature deviations compared to E-MPC.

The performance of the AE-MPC scheme is compared to E-MPC in Figure 3. During an initial phase, AE-MPC has a larger cost due to noise amplification in the adaptation. However, after this transient phase, AE-MPC achieves consistently significantly better performance due to the improved model estimate. In contrast, the performance of E-MPC consistently suffers due to the wrong parameter estimate. These results are consistent with Theorem 5, showing that the effect of the initial parameter error vanishes as $T \rightarrow \infty$.

Overall, this numerical examples demonstrates that the proposed AE-MPC can enhance the economic performance during operation under persistent disturbances and parametric uncertainty.

²https://gitlab.ethz.ch/mdegner/ae-mpc-for-linear-systems



Fig. 3. Performance of AE-MPC (blue) and E-MPC (orange): Accumulated cost (top) and stage costs (bottom).

VI. CONCLUSION

A computationally and conceptually simple adaptive economic MPC scheme has been proposed for linear systems with parametric uncertainty and additive, bounded disturbances. We used a projected LMS filter for the online model adaptation and derived theoretical performance guarantees for the asymptotic and the transient case. In particular, we showed for finite-energy disturbances that asymptotically, AE-MPC has the same performance guarantee as nominal economic MPC with perfect knowledge of the parameters.

The presented AE-MPC scheme with its strong theoretical performance guarantees forms a natural basis for future investigation of adaptive optimal control. Future work includes the consideration of parameter dependent optimal steady-states using ideas from adaptive MPC [23] and more general economic MPC schemes [32, Chap. 5].

REFERENCES

- J. B. Rawlings, D. Q. Mayne, and M. Diehl, *Model Predictive Control: Theory, Computation and Design*, 2nd ed. Nob Hill Publishing, LLC, 2020.
- [2] M. Morari and J. H. Lee, "Model predictive control: past, present and future," *Computers & chemical engineering*, vol. 23, no. 4-5, pp. 667–682, 1999.
- [3] J. B. Rawlings, D. Angeli, and C. N. Bates, "Fundamentals of economic model predictive control," in *Proc. 51st IEEE Conference* on Decision and Control (CDC). IEEE, 2012, pp. 3851–3861.
- [4] T. Faulwasser, L. Grüne, M. A. Müller et al., "Economic nonlinear model predictive control," Foundations and Trends[®] in Systems and Control, vol. 5, no. 1, pp. 1–98, 2018.
- [5] J. Köhler, M. A. Müller, and F. Allgöwer, "Periodic optimal control of nonlinear constrained systems using economic model predictive control," *Journal of Process Control*, vol. 92, pp. 185–201, 2020.
- [6] T. Faulwasser and G. Pannocchia, "Toward a unifying framework blending real-time optimization and economic model predictive control," *Industrial & Engineering Chemistry Research*, vol. 58, no. 30, pp. 13 583–13 598, 2019.
- [7] S. Taheri, P. Hosseini, and A. Razban, "Model predictive control of heating, ventilation, and air conditioning (HVAC) systems: A state-ofthe-art review," *Journal of Building Engineering*, vol. 60, p. 105067, 2022.
- [8] M. J. Risbeck, C. T. Maravelias, and J. B. Rawlings, "Unification of closed-loop scheduling and control: State-space formulations, terminal constraints, and nominal theoretical properties," *Computers & Chemical Engineering*, vol. 129, p. 106496, 2019.
- [9] D. Angeli, R. Amrit, and J. B. Rawlings, "On Average Performance and Stability of Economic Model Predictive Control," *IEEE Transactions on Automatic Control*, vol. 57, no. 7, pp. 1615–1626, Jul. 2012.

- [10] R. Amrit, J. B. Rawlings, and D. Angeli, "Economic optimization using model predictive control with a terminal cost," *Annual Reviews* in Control, vol. 35, no. 2, pp. 178–186, 2011.
- [11] L. Grüne and M. Stieler, "Asymptotic stability and transient optimality of economic mpc without terminal conditions," *Journal of Process Control*, vol. 24, no. 8, pp. 1187–1196, 2014.
- [12] L. Grüne and A. Panin, "On non-averaged performance of economic mpc with terminal conditions," in *Proc. 54th IEEE Conference on Decision and Control (CDC)*. IEEE, 2015, pp. 4332–4337.
- [13] F. A. Bayer, M. A. Müller, and F. Allgöwer, "On optimal system operation in robust economic mpc," *Automatica*, vol. 88, pp. 98–106, 2018.
- [14] L. Schwenkel, J. Köhler, M. A. Müller, and F. Allgöwer, "Robust economic model predictive control without terminal conditions," *IFAC-PapersOnLine*, vol. 53, no. 2, pp. 7097–7104, 2020.
- [15] C. Klöppelt, L. Schwenkel, F. Allgöwer, and M. A. Müller, "Transient performance of tube-based robust economic model predictive control," *IFAC-PapersOnLine*, vol. 54, no. 6, pp. 28–35, 2021.
- [16] T.-W. Yoon and D. W. Clarke, "Adaptive predictive control of the benchmark plant," *Automatica*, vol. 30, no. 4, pp. 621–628, 1994.
- [17] D. Q. Mayne, "Model predictive control: Recent developments and future promise," *Automatica*, vol. 50, no. 12, pp. 2967–2986, 2014.
 [18] M. Lorenzen, M. Cannon, and F. Allgöwer, "Robust MPC with
- [18] M. Lorenzen, M. Cannon, and F. Allgöwer, "Robust MPC with recursive model update," *Automatica*, vol. 103, pp. 461–471, May 2019.
- [19] J. Köhler, E. Andina, R. Soloperto, M. A. Müller, and F. Allgöwer, "Linear robust adaptive model predictive control: Computational complexity and conservatism," in *Proc. 58th IEEE Conf. Decision* and Control (CDC), 2019, pp. 1383–1388, extended version on arXiv:1909.01813.
- [20] X. Lu, M. Cannon, and D. Koksal-Rivet, "Robust adaptive model predictive control: Performance and parameter estimation," *International Journal of Robust and Nonlinear Control*, vol. 31, no. 18, pp. 8703– 8724, 2021.
- [21] G. A. Gonçalves and M. Guay, "Robust discrete-time set-based adaptive predictive control for nonlinear systems," *Journal of Process Control*, vol. 39, pp. 111–122, 2016.
- [22] J. Köhler, P. Kötting, R. Soloperto, F. Allgöwer, and M. A. Müller, "A robust adaptive model predictive control framework for nonlinear uncertain systems," *International Journal of Robust and Nonlinear Control*, vol. 31, no. 18, pp. 8725–8749, 2021.
- [23] A. Sasfi, M. N. Zeilinger, and J. Köhler, "Robust adaptive mpc using control contraction metrics," *Automatica*, vol. 155, p. 111169, 2023.
- [24] R. Soloperto, M. A. Muller, and F. Allgower, "Guaranteed Closed-Loop Learning in Model Predictive Control," *IEEE Transactions on Automatic Control*, vol. 68, no. 2, pp. 991–1006, Feb. 2023.
- [25] R. Zuliani, R. Soloperto, and J. Lygeros, "Convergence guarantees for adaptive model predictive control with kinky inference," *arXiv preprint* arXiv:2312.11329, 2023.
- [26] A. Marchetti, B. Chachuat, and D. Bonvin, "Modifier-adaptation methodology for real-time optimization," *Industrial & engineering chemistry research*, vol. 48, no. 13, pp. 6022–6033, 2009.
- [27] M. L. Shaltout, Z. Ma, and D. Chen, "An Adaptive Economic Model Predictive Control Approach for Wind Turbines," *Journal of Dynamic Systems, Measurement, and Control*, vol. 140, no. 5, p. 051007, May 2018.
- [28] M. Vaccari, D. Bonvin, F. Pelagagge, and G. Pannocchia, "Offset-free economic mpc based on modifier adaptation: Investigation of several gradient-estimation techniques," *Processes*, vol. 9, no. 5, p. 901, 2021.
- [29] E. Oliveira-Silva, C. de Prada, D. Montes, and D. Navia, "Economic MPC with modifier adaptation using transient measurements," *Computers & Chemical Engineering*, vol. 173, p. 108205, May 2023.
- [30] M. Wu, "Learning-based economic control for repetitive systems," Ph.D. dissertation, 2023.
- [31] Z. Wang, Y. Chen, and Y. Li, "Development of RC model for thermal dynamic analysis of buildings through model structure simplification," *Energy and Buildings*, vol. 195, pp. 51–67, Jul. 2019.
- [32] J. Köhler, M. A. Müller, and F. Allgöwer, "Analysis and design of model predictive control frameworks for dynamic operation—an overview," *Annual Reviews in Control*, vol. 57, p. 100929, 2024.

APPENDIX

The following auxiliary results are used in the proof of Theorem 3.

Lemma 6 (Limits of infinite series [24, Lemma 1]). For any sequence (a_k) that satisfies $0 \le a_k \le a_{\max} < \infty \ \forall k \in \mathbb{N}$ and any function $\alpha \in \mathcal{K}_{\infty}$, the following implication holds:

$$\lim_{T \to \infty} \sum_{k=0}^{T-1} a_k \le S < \infty \Rightarrow \lim_{T \to \infty} \sum_{k=0}^{T-1} \frac{\alpha(a_k)}{T} = 0$$
(30)

This lemma links uniformly bounded sequences to asymptotic averages. It supports the inference of explicit bounds for the prediction error and the disturbances.

Lemma 7 (Asymptotic convergence of prediction error). *Let Assumption 2 hold. Then,*

$$\lim_{T \to \infty} \frac{\sum_{k=0}^{T-1} \|\tilde{x}_{1|k}\| + \|w_k\|}{T} = 0.$$

Proof. We know by assumption that $\sum_{k=0}^{T} \|w_k\|^2 \leq S_w < \infty$. We can now use Lemma 6 with $a_k = \|w_k\|^2$ and $\alpha(s) = \sqrt{s}, \alpha \in \mathcal{K}_\infty$ to get:

$$\lim_{T \to \infty} \sum_{k=0}^{T-1} \frac{\sqrt{\|w_k\|^2}}{T} = \lim_{T \to \infty} \sum_{k=0}^{T-1} \frac{\|w_k\|}{T} = 0.$$
(31)

Furthermore, $\frac{1}{\mu} \|\hat{\theta}_0 - \theta^*\|^2 < \infty$ since Θ is compact implies

$$\sum_{k=0}^{T-1} \|\tilde{x}_{1|k}\|^2 \stackrel{(7)}{\leq} S_{\mathbf{w}} + \frac{1}{\mu} \|\hat{\theta}_0 - \theta^*\|^2 < \infty.$$

Applying Lemma 6 with $a_k = \|\tilde{x}_{1|k}\|^2$ yields

$$\lim_{T \to \infty} \sum_{k=0}^{T-1} \frac{\sqrt{\|\tilde{x}_{1|k}\|^2}}{T} = \lim_{T \to \infty} \sum_{k=0}^{T-1} \frac{\|\tilde{x}_{1|k}\|}{T} = 0.$$
(32)

Adding (31) and (32) yields the desired inequality. \Box